Annexure D

BUILDING SAFETY CERTIFICATE

Ref. No 4870A/1C/26 Dated: 10-03-2026

It is certified that the existing building **Delhi Public School**, at **NH-19, (Old NH-2), Agra Road, Etawah** is having block(s)/Floor(s) as per details below:

Detail of Block(s) in School	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	**04**	**x**	**x**	**x**	**x**	**x**

The building is owned/occupied by **Delhi Public School** have complied with the Building safety requirements in accordance with National Building code Rules, and verified by the officers concerned of **P.W.D.** on **07/03/2026** in the presence of **Dr. Vivek Yadav, 234 C, Friends Colony, Etawah** and that the building/premises is fit for occupancy for running school with effect from **07/03/2026** for a period of **3 years** in accordance with rule and subject to compliance of the specific conditions as appended.

1. Two doors in every class room with the size of wide 1.60m & height 2.60m minimum.
2. Fire Safety System working properly.
3. Staircases and emergency exit as per norms
4. Structural condition of building found satisfactory

Issued on 07/03/2026 at Etawah by

* Strike out whichever is not applicable. In case of block is more t han six use separate sheet for detail.

Signature with Seal : 10103326 सहायक अभियन्ता निर्माण खण्ड-1, लो०नि०वि० इटावा

Name : Gaurav Jain

Designation : Assistant Engg.

Name & Address of Department/ Office: UPPWD

Scanned with OKEN Scanner