Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 1353 /NPPE-Sa.D./2025-26 Dated : 18/02/26

It is certified that an inspection team headed by **Natthi Lal, Chief Sanitation And Food Inspector** (Name of Officers with designation) from **Nagar Palika Parishad, Etawah**. PHED inspected the **DELHI PUBLIC SCHOOL, N.H.-2, Agra Road, Etawah** (Name & Address of the school) on **12/02/2026** (date of inspection) on the basis of Water Test Report (Attached) bearing no. **TC-17043-26000000047F** Dated **17/02/2026 of District Level Water Analysis Laboratory Uttar Pradesh Jal Nigam (Rural), Near Police Line, Etawah** (PHED Lab) certified that the **DELHI PUBLIC SCHOOL** (Name of school) that has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U T Govt.

This certificate is valid till : 31/03/2027

Signature with Seal पुष्प... सफाई निरीक्षक.....
Name : **Natthi Lal** नगर पालिका परिषद, इटावा
Designation : **Chief Sanitation And Food Inspector**
Nagar Palika Parishad, Etawah
Name & Address of the Office/ Department

To,

DELHI PUBLIC SCHOOL
N.H.-2, Agra Road, Etawah

Note : The certificate is to be issued by authorized officer/ PHED Lab/local bodies.

Scanned with OKEN Scanner

District Level Water Analysis Laboratory
Uttar Pradesh Jal Nigam (Rural),
Near Police Line, Etawah

TC-17043

Analysis Water Test Report

ULR No.	TC- 17043-26000000047F	Chemical Test/47	Date: 17/02/2026	Page No.	1

Customer Details

Office Name & Address	Delhi Public School NH-2 Agra Road Etawah
Ref. Letter No. & Date	DPS /E.E /J.N/ETW/12226 12/02/2026

Basic Details of Sample

District	Etawah	Block	Badhpura
Gram Panchayat	Doongri	Village	Doongri
Habitation	-	Location	Delhi Public School
Water Source	Submersible	Lab Code & Sample code	ETW/26/02/1P(06429)
Quantity of Sample	2 Liter	Date of S.C	12/02/2026
Receiving Date	12/02/2026	S. Collector	Sanjeev Yadav
Sample Depositor	Sanjeev Yadav	Analysis Completion Date	13/02/2026
Analysis Start Date	12/02/2026		

Environmental Condition

Temperature	25±3°C	Humidity	50±15%

Technical Data of Analysis

S. No.	Analyzed Parameters	Observed Value	Specified Values as per BIS 10500:2012		Sampling Method	IS 17614 (Part-1) :2025
			Acceptable Limit	Permissible	Ref. Method of Analysis	IS 3025 & APHA
1	Odour	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025(Part 5): 2023	
2	Taste	Agreeable	Agreeable	Agreeable/Not Agreeable	IS3025 (Part 7): 2023	
3	Colour	5	5	15	IS3025(Part -4)2021	
4	Turbidity (NTU)	0.11	1	5	IS3025(Part-10) :2023 (Nephelometric method)	
5	PH (25°C)	7.62	6.5	8.5	IS3025(Part11) :2022 (Electrometric Method)	
6	TDS (Mg/L)	110	500	2000	IS3025 (Part 16):2023 (Gravimetric Method)	
7	Alkalinity (Mg/L)	40	200	600	IS3025(Part-23) :2023 (indicator Method)	
8	Total Hardness (Mg/L)	60	200	600	IS3025(Part-21) :2023 (EDTA)	
9	Sulphate (Mg/L)	7.92	200	400	IS3025(Part-24) :2022	
10	Nitrate (Mg/L)	0.71	45	No Relaxation	APHA Method 24rd Addition 4500 : 2023	
11	Iron (Mg/L)	0.20	1.0	No Relaxation	IS3025 (Part-53) : 2024(1,10 Phenanthroline Method)	
12	Chloride (Mg/L)	25.99	250	1000	IS3025)Part-32) :2019	
13	Magnesium (Mg/L)	8.16	30	100	IS3025(Part-46):2023	
14	Calcium (Mg/L)	10.42	75	200	IS3025(Part-40):2023	

Note:-
1-This Certificate refers only to the particular sample (s) submitted for testing.
2- This Certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory
3-The test result reported in this certificate are valid at the time of and under the stated conditions of measurements.
4-Sample will be stored up to 7 days (in case of non-perishable items only) from the date of issue of test reports unless otherwise specified.
5-Parameters above permissible limit are written in Bold.

Report Prepared By
Pradeep Kumar
DQM / DTM

Authorized Signatory
Quality Manager
(Shivam Kumar Verma)
Quality Manger/Technical Manager
Mob-8126544535

Laboratory Contact Details Email-etawahlab@gmail.com

End Of Report

Scanned with OKEN Scanner

District Level Water Analysis Laboratory

Uttar Pradesh Jal Nigam (Rural), Near Police Line, Etawah.

Issue No. : 03
Issue Date- 17/02/2026

Report /Sample Code/Lab Code	*Bacteria Test/ ETW/26/02/B/1P (9642P)*	District	Etawah
Office Name & Address	Delhi Public School NH-2 Agra Road Etawah	Block	Badhpura
Gram Panchayat	Doongri	Village	Doongri
Habitation	-	Location	Delhi Public School Etawah
Water Source	Submersible	Sample No	1
Quantity of Sample	2 Liter	Date Of Collection	12/02/2026 P
Receiving Date	09/02/2026	Sample Collector	Sanjeev Yadav
Sample Depositor	Sanjeev Yadav	Sampling Method	-
Analysis Start Date	12/02/2026	Analysis Completion	13/02/2026
Temperature	25±3^{0}C	Humidity	50±15%

Technical Data Of Analysis

Sr.No.	Analysed Parameter	Observed Value	Specified Values as Per BIS 10500:2012		Ref. Method of analysis
			Acceptable Limit	Permissible Limit	
1.	pH (25^{0}C)	7.62	6.5-8.5	No relaxation	IS 3025(Part-11)2022
2.	Residual Chlorine (Mg/L)	0.1	0.20	1.00	IS 3025(Part-26)2022
3.	Total Coliform (CFU)	0.0	No relaxation	No relaxation	IS 15185:2016
4.	E .Coli (CFU)	0.0	No relaxation	No relaxation	IS 15185:2016

Note:

1. This certificate refers only to the particular sample submitted for testing.
2. This certificate shall not be reproduced, except in full unless written permission of an approved has been Obtained from Head of Laboratory.
3. The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
4. Samples will be stored up to 07 days (in case of non –perishable items only) from the date of issue.

(Tested & Checked By)
Mohd. Ateeq
Microbiologist

(Approved By)
Shivam Kumar Verma
Quality Manager / Technical Manager

End of Report

Scanned with OKEN Scanner